


## FIRE SUPPRESSION SHUTDOWN 12

NOT TO SCALE E-400




## TIME CLOCKS 11

NOT TO SCALE E-400




## FREEZER LTG & DOOR HTR WIRING DIAGRAM 10

NOT TO SCALE E-400




## FREEZER EVAPORATOR COIL 9

NOT TO SCALE E-400




## COOLER EVAPORATOR COIL 8

NOT TO SCALE E-400




## CONDENSING UNIT 7

NOT TO SCALE E-400

1. WIRING SHOULD BE DONE ACCORDING WITH NATIONAL AND LOCAL CODE.

2. CHECK VOLTAGE ON CONDENSING UNIT AND EVAPORATOR COIL BEFORE ANY WORK IS DONE.

3. SOLID LINES TO BE WIRED BY LICENSED ELECTRICIAN ON SITE. DOTTED LINES ARE MANUFACTURE PRE-WIRED.

4. ANY PENETRATIONS THROUGH BOX SHALL BE SEALED AIR TIGHT.

## WIC / WIF WIRING DIAGRAM NOTES 6

NOT TO SCALE E-400




NOTE: EXHAUST FAN TO OPERATE WITH KITCHEN LIGHTS TO REGULATE BUILDING PRESSURE.

## EXHAUST FAN CONTROL DIAGRAM 5

NOT TO SCALE E-400




## LIGHT FIXTURE DETAIL 4

NOT TO SCALE E-400

### DEVICE ORIENTATION




### DEVICE & COVERPLATE COLOR

| LOCATION | DEVICE COLOR | COVER PLATE COLOR | NOTES |
|---|---|---|---|
| DINING ROOM (WALLS) | VERIFY W/PX | VERIFY W/PX | VERIFY WITH PANDA PM PRIOR TO PURCHASE AND INSTALL |
| DINING ROOM (IN BULKHEAD ABOVE WINDOWS) | VERIFY W/PX | VERIFY W/PX | VERIFY WITH PANDA PM PRIOR TO PURCHASE AND INSTALL |
| DINING ROOM (WHEN IN CEILING) | BLACK | BLACK | @ SHOW WINDOW IN DARK CEILING (IF APPLICABLE) |
| RESTROOM | GREY | STAINLESS STEEL | -- |
| RESTROOM VESTIBULE | GREY | STAINLESS STEEL | -- |
| KITCHEN/SERVICE AREAS | GREY | STAINLESS STEEL | -- |

## DEVICE / RECEPTACLE SCHEDULE 3

NOT TO SCALE E-400




## ANSUL PULL STATION DETAIL 2

NOT TO SCALE E-400




## PANEL 'A' GROUNDING DETAIL 1

NOT TO SCALE E-400

PANDA EXPRESS, INC.
1683 Walnut Grove Ave.
Rosemead, California
91770
Telephone: 626.799.9898
Facsimile: 626.372.8288

All ideas, designs, arrangement and plans indicated or represented by this drawing are the property of Panda Express Inc. and were created for use on this specific project. None of these ideas, designs, arrangements or plans may be used by or disclosed to any person, firm, or corporation without the written permission of Panda Express Inc.

REVISIONS:

ISSUE DATE:

| | | |
|---|---|---|
| | STATE PERMIT | 06.07.21 |

DRAWN BY: G. COLLINS

PANDA PROJECT #: D8060

ARCH PROJECT #: JCDT20-0240

STEVEN PATRICK FICKELL REGISTERED No. PE11800680 STATE OF INDIANA PROFESSIONAL ENGINEER
6-7-21

NORR ARCHITECTS ENGINEERS PLANNERS

PANDA EXPRESS
TRUE WARM & WELCOME
390 W Spring Mill Pointe Dr.
Westfield, IN 46074

# E-400

ELECTRICAL DETAILS, DIAGRAMS